



DECLARATION OF PERFORMANCE

According to
Construction Products Regulation
EU N° 305/2011

1. Unique identification code of the product-type:

Dorgard

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):

1328-A01

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Electrically powered hold-open device for fire/smoke swing doors

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Fireco Ltd
Head Office
Preece House
Davigdor Road
Brighton
BN3 1RE
UNITED KINGDOM**

Tel. +44 1273 320650

Fax: +44 1273 320655

Email: info@firecoltd.com

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:


System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:
- EN1155: 1997 A1: 2002**
Warrington Certification Ltd 1121
8. European Technical Assessment **N/A**
9. Declared performance **See table**
10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.
See table

Essential Characteristics	Performance	Harmonised Technical Specification
Hold Open		EN 1155: 1997: A1: 2002
5.2.1 General	Size 7 Closer, 160Kg Door	
5.2.2 Electrical Release	Pass	
5.2.3 Door Closer Requirements	Not Applicable	
5.2.4 Durability	Pass (500,000 test cycles)	
5.2.5 Angle of hold	Pass	
5.2.6 Manual Release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload Performance	Pass 160Kg door	
5.2.9 Delayed Release	Not Applicable	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire Door Suitability	Pass	
5.1.14.1 Corrosion Resistance	NPD	
5.2.14.2 Electrical release after neutral salt spray test	Yes	

Signed for and on behalf of the manufacturer by:

Mr Neil Purssey, Executive Chairman



Brighton, United Kingdom. June 2013